

Overload Relay

Full Load Motor Amps^①

Table 111

Size			Heater Code
00, 0, 1	1P	2, 2½	
—	—	—	H1
—	—	—	H2
0.42-0.47	—	—	H3
0.48-0.52	—	—	H4
0.53-0.57	—	—	H5
0.58-0.63	—	—	H6
0.64-0.69	—	—	H7
0.70-0.77	—	—	H8
0.78-0.85	—	—	H9
0.86-0.95	0.86-0.95	—	H10
0.96-1.06	0.96-1.06	—	H11
1.07-1.19	1.07-1.19	—	H12
1.20-1.33	1.20-1.33	—	H13
1.34-1.46	1.34-1.46	—	H14
1.47-1.63	1.47-1.63	—	H15
1.64-1.77	1.64-1.77	—	H16
1.78-2.00	1.78-2.00	—	H17
2.01-2.18	2.01-2.18	—	H18
2.19-2.34	—	—	H19
2.35-2.55	2.19-2.55	—	H20
2.56-2.77	2.56-2.77	—	H21
2.78-3.10	2.78-3.10	—	H22
3.11-3.52	3.11-3.52	—	H23
3.53-3.90	3.53-3.90	—	H24
3.91-4.40	3.91-4.40	—	H25
4.41-4.94	4.41-4.94	—	H26
4.95-5.46	4.95-5.46	—	H27
5.47-6.12	5.47-6.12	—	H28
6.13-6.96	6.13-6.96	—	H29
6.97-7.60	6.97-7.60	—	H30
7.61-8.40	7.61-8.40	—	H31
8.41-9.64	8.41-9.64	—	H32
9.65-11.0	9.65-11.0	12.1-13.9	H33
11.1-11.4	11.1-11.4	14.0-15.2	H34
11.5-12.6	11.5-12.6	15.3-16.2	H35
12.7-13.4	12.7-13.4	16.3-17.6	H36
13.5-15.1	13.5-15.1	17.7-20.3	H37
15.2-16.3	15.2-16.3	20.4-21.3	H38
16.4-17.2	16.4-17.2	21.4-22.5	H39
17.3-19.7	17.3-19.7	22.6-25.1	H40
19.8-22.5	19.8-22.5	25.2-28.9	H41
22.6-24.7	22.6-25.5	29.0-33.3	H42
—	25.6-28.5	33.4-37.0	H43
—	28.6-32.1	37.1-42.4	H44
—	32.2-35.0	42.5-46.0	H45
—	—	46.1-51.7	H46
—	—	51.8-56.4	H48
—	—	56.5-60.0	H49